



POOL CHEMISTRY REQUIREMENTS:

	Pool/Activity Pool		Whirlpool or Therapy Pool		Wading Pool		Plunge/Wave Pool		Water Attraction		Interactive Play		Waterslides	
	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
Free Chlorine (FC)	1.0	10.0	3.0	10.0	2.0	10.0	2.0	10.0	1.0	10.0	2.0	10.0	2.0	10.0
FC w/stabilizer	2.0	10.0	6.0	10.0	4.0	10.0	4.0	10.0	2.0	10.0	4.0	10.0	4.0	10.0
FC w/monitoring	1.0	10.0	3.0	10.0	1.0	10.0	1.0	10.0	1.0	10.0	1.0	10.0	1.0	10.0
Bromine	3.0	10.0	4.0	10.0	4.0	10.0	3.0	10.0	3.0	10.0	3.0	10.0	3.0	10.0
Bromine w/monitoring	3.0	10.0	4.0	10.0	3.0	10.0	3.0	10.0	3.0	10.0	3.0	10.0	3.0	10.0
pH	7.2	7.8	7.2	7.8	7.2	7.8	7.2	7.8	7.2	7.8	7.2	7.8	7.2	7.8
Alkalinity	60.0	180.0	60.0	180.0	60.0	180.0	60.0	180.0	60.0	180.0	60.0	180.0	60.0	180.0
Temp	72.0	95.0	72.0	95.0	72.0	95.0	72.0	95.0	72.0	95.0	72.0	95.0	72.0	95.0
ORP	650	900	650	900	650	900	650	900	650	900	650	900	650	900
Cyanuric Acid	0	30	0	30	0	30	0	30	0	30	0	30	0	30
SI	-0.3	0.5	-0.3	0.5	-0.3	0.5	-0.3	0.5	-0.3	0.5	-0.3	0.5	-0.3	0.5
Calc	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Turnover Rate		6.0		0.5		2.0		2.0		6.0		6.0		6.0
Combined Chlorine	<i>Plan in place to minimize CC. Recommended action level of 0.4PPM</i>													

TESTING REQUIREMENTS:

	Whirlpools/Therapy/Exercise	All other Pools
Disinfectant	1x before open and 3x/day	1x before open and 1x/day
Disinfectant w/monitoring	1x/day	1x/day
pH	1x before open and 3x/day	1x before open and 1x/day
pH w/monitoring	1x/day	1x/day
Combined Chlorine	1x/day	2x/week
Alkalinity	1x/week	1x/week
Cyanuric Acid	1x/week	1x/week